

**From:** [celestenov@aol.com](mailto:celestenov@aol.com) [<mailto:celestenov@aol.com>]

**Sent:** Tuesday, July 08, 2014 1:43 PM

**To:** Thacher, Jill

**Cc:** [jallen@monalbuilds.com](mailto:jallen@monalbuilds.com); [pvl@umich.edu](mailto:pvl@umich.edu); [rjlehman@umich.edu](mailto:rjlehman@umich.edu)

**Subject:** Lehman addition: Addendum to the Historic Distric Commission Application

Dear Jill,

I appreciate your visit to the site yesterday. I am writing to clarify two details and request one change to the plans. The siding on the new addition will be a narrow profile, 6 - 8" to match the profile of the existing wood siding originally on the residence. Once we remove the aluminum siding to begin the new addition, I will know the exact dimension. The upper bedroom will retain the existing window and although the drawing on the rear elevation appears to be another window added to the bedroom, this is drawn incorrectly and is in fact, a door. As listed in the packet, this door is the Countryside door with a screen as shown in the application.

We will adjust the drawings of the deck rail to reflect the bottom rail as flat as recommended by the commission.

I would like to ask permission to adjust the length of the addition. The plans currently show the addition extending 15'-6" from the rear of the building. We will need to add a wall in the bathroom and adjust the area for the washer/dryer and would like leeway to allow for the addition to be no larger than 17'-0" from the rear of the building.

Thank you for this consideration and I look forward to presenting this project to the commission. Do I need to prepare any additional sketches for this meeting?

thanks again.

Celeste

**celeste allen novak FAIA**  
**celeste allen novak architect pllc**

1066 Knight Road

Ann Arbor, MI 48103

734 846-3903c 734 747-7407

**Author:** *"Designing Rainwater Harvesting Systems: Integrating Rainwater Into Building Systems"* To be published by Wiley - April 2014.