

ADDENDUM No. 1

ITB No. 4380

WATER TREATMENT PLANT CHEMICAL BID LIQUID OXYGEN (LOX)

Due: April 30, 2015 at 2:00PM

The following changes, additions, and/or deletions shall be made to the Invitation to Bid for Water Treatment Plant Chemical Bid, Liquid Oxygen (LOX), ITB No. 4380, on which proposals will be received on/or before April 30, 2015 by 2:00 p.m.

The information contained herein shall take precedence over the original documents and all previous addenda (if any), and is appended thereto. **This Addendum includes 1 page.**

Bidder is to acknowledge receipt of this Addendum No. 1, including all attachments (if any) in its Bid by so indicating on the Invitation to Bid Form. Bids submitted without acknowledgement of receipt of this addendum will be considered nonconforming.

I. ADDITIONS

Changes to the Bid documents which are outlined below are referenced to a page or Section in which they appear conspicuously. The Bidder is to take note in its review of the documents and include these changes as they may affect work or details in other areas not specifically referenced here.

Section 2 Specifications Part 2.3 Impurities should include the following:

Oxygen is a direct additive used in the treatment of potable water. This material shall be certified as suitable for contact with or treatment of drinking water by an accredited certification organization in accordance with ANSI/NSF Standard 60, Drinking Water Treatment Chemicals-Health Effects.