

Community Services Area Planning & Development Services Unit 301 East Huron, P.O. Box 8647, Ann Arbor, Michigan 48107-8647 Phone: (734) 794-6261 Fax: (734) 994-8460

January 4, 2016

Louis Feigelson PO Box 7262 Ann Arbor, MI 48107

Re:

111 South Main Street, Ann Arbor, Michigan

Parcel Identification Number ("PIN"): 09-09-29-132-014

Dear Mr. Feigelson:

Please consider this as a reminder to attend the Ann Arbor Building Board of Appeals meeting for your Show Cause hearing for your property at 111 South Main Street.

The meeting will take place on Wednesday, January 13, 2016 at 1:30 PM on the 2nd floor of City Hall in the City Council Chambers. Please bring materials and interested parties to the meeting for your presentation to the Board if needed.

Sincerely,

Craig Strong, Building Official City of Ann Arbor Construction Services cstrong@a2gov.org

(734)794-6261



Community Services Area
Planning & Development Services Unit
301 East Huron, P.O. Box 8647,
Ann Arbor, Michigan 48107-8647
Cstrong@a2gov.org

DANGEROUS BUILDING ORDER TO SHOW CAUSE ON DECEMBER 18, 2015 AT 1:30 P.M.

December 07, 2015

BY CERTIFIED MAIL, FIRST CLASS MAIL, & POSTING

Louis M. Feigelson P.O. Box 7262 Ann Arbor, MI 48107

Re.

111 South Main Street, Ann Arbor, Michigan

Parcel Identification Number ("PIN"): 09-09-29-132-014

Dear Mr. Feigelson:

A Dangerous Building Notice and Order, a copy of which is enclosed and made part of this Order to Show Cause, was served on you on the date indicated informing you that the building that you own and/or have an interest in at the above-referenced address is a dangerous building, as defined in Section 8:382 of the Ann Arbor City Code. Your building was deemed dangerous pursuant to the provisions listed in the enclosed Notice and Order due to the conditions listed therein.

Inspection reveals that you have not undertaken the work necessary to demolish the building or to otherwise make it safe.

Therefore, this is your notice that a public hearing, which you and/or your attorney are ordered to attend, will be conducted by the Ann Arbor Building Board of Appeals on **December 18, 2015**, at **1:30 p.m.** on the **6th floor Conference Room** in the Ann Arbor City Hall. At the hearing you will have an opportunity to show cause why you should not be required to demolish or otherwise make safe the building at the above-referenced address, which is more specifically described as follows:

N 21.5 FT LOT 5 B1S R4E ORIGINAL PLAT OF ANN ARBOR

The Building Board of Appeals will take your testimony and the testimony of any other interested persons. Please bring any evidence you wish to submit to the Board.

A copy of this Dangerous Building Order to Show Cause is being filed with the Washtenaw County Register of Deeds. If there are any other parties known to the City who may have an interest in your property, a copy is also being sent by certified and first class mail to the addresses indicated below.

The Ann Arbor City Hall is located at 301 East Huron, Ann Arbor Michigan.

If you have any questions please contact me by e-mail or phone.

Sincerely.

Craig Strong, building Official
City of Ann Arbor Construction Services

cstrong@a2gov.org

Enclosures

cc (w/enclosure) by certified and first class mail to:

Louis M. Feigelson, 1258 Crosby Crescent, Ann Arbor, MI 48103

Courtesy copy (w/attachment and enclosure) by first class mail to:

David A. Nacht Joseph X. Michaels, Nacht, Roumel, Salvatore, Blanchard & Walker, P.C. 101 North Main Street, Suite 555 Ann Arbor, Michigan 48104

cc: Sumedh Bahl, Community Services Area Administrator Kristen D. Larcom, Senior Asst. City Attorney



Community Services Area
Planning & Development Services Unit
301 East Huron, P.O. Box 8647,
Ann Arbor, Michigan 48107-8647
Phone: (734) 794-6261
Fax: (734) 994-8460

September 17, 2015

Louis M. Feigelson PO Box 7262 Ann Arbor, MI 48107

Re:

111 South Main Street, Ann Arbor, Michigan

Parcel Identification Number ("PIN"): 09-09-29-132-014

Dear Mr. Feigelson:

Please consider this as a reminder to attend the Ann Arbor Building Board of Appeals meeting for your Dangerous Building Notice and Order for the conditions at 111 S Main.

The meeting will take place on Thursday, September 24, 2015 at 1:30 PM on the 2nd floor of City Hall in the Council Chambers. Please bring materials and interested parties to the meeting if needed.

Sincerely,

Craig Strong, Building Official

City of Ann Arbor Construction Services

cstrong@a2gov.org



Community Services Area
Planning & Development Services Unit
301 East Huron, P.O. Box 8647,
Ann Arbor, Michigan 48107-8647
Fax: (734) 994-8460
cstrong@a2gov.org

DANGEROUS BUILDING NOTICE AND ORDER

September 3, 2015

BY CERTIFIED MAIL, FIRST CLASS MAIL, & POSTING

Louis M. Feigelson P.O. Box 7262 Ann Arbor, MI 48107

Re.

111 South Main Street, Ann Arbor, Michigan

Parcel Identification Number ("PIN"): 09-09-29-132-014

Dear Mr. Feigelson:

Records of the Ann Arbor City Assessor and the Washtenaw County Register of Deeds indicate that you are the owner of the property located within the City of Ann Arbor at the above-referenced address. The property is more fully described in the Assessor's Records as follows:

N 21.5 FT LOT 5 B1S R4E ORIGINAL PLAT OF ANN ARBOR

This letter is to provide notice that the City finds that the building on the property is a dangerous building as defined in provisions of **Section 8:382** of **Chapter 101** of the Ann Arbor City Code, including but not limited to subsections 1-7, 9, and 10. A copy of Chapter 101 is enclosed. Specific defects that render the building[s] dangerous include, but are not limited to, the following:

- significant water damage to the structure
- saturation of the plywood flooring throughout the visible portions of the west 60' and damage to floor joists
- large tree growing from the roof
- framing around tree is severely damaged

- majority of plywood subfloor is damaged beyond repair due to water saturation and not adequate as a subfloor material or bracing material to the joists below
- joists in the floor have an unbraced compression flange and do not meet strength requirements required for the loading
- localized rotting at the bearing points of the joists where water could accumulate
- gross amount of mold growing throughout the building may make other dangerous conditions not visible
- the structure does not meet building code requirements
- Building has been unoccupied for 180 days or more without being listed for sale or lease

It is requested that you contact the Building Official by the end of the business day on September 15, 2015 to discuss your intentions for demolishing or repairing the buildings listed above.

If there are any other parties known to the City who may have an interest in your property, a copy of this Notice and Order is being sent by certified and first class mail to the addresses indicated below.

Failure to respond and/or to remedy the violations will result in a recommendation for you to appear at a future meeting of the Building Board of Appeals.

Because of the immediacy of these health and safety concerns, it is highly recommended that a dialogue be initiated at the earliest instance between the property owner/parties in interest and the Building Official. I can be reached by email or telephone.

Sincerely,

Craig Strong, Acting Building Official
City of Ann Arbor Construction Services

Email: cstrong@a2gov.org

Enclosure (Dangerous Buildings Ordinance)

cc (w/ enclosure) by certified and first class mail to:

Louis M. Feigelson, 1258 Crosby Crescent, Ann Arbor, MI 48103

Courtesy copy (w/attachment and enclosure) by first class mail to:

David A. Nacht Joseph X. Michaels, Nacht, Roumel, Salvatore, Blanchard & Walker, P.C. 101 North Main Street, Suite 555 Ann Arbor, Michigan 48104

cc: Sumedh Bahl, Community Services Area Administrator Kristen D. Larcom, Senior Asst. City Attorney



Community Services Area
Planning and Development Service Unit
Rental Housing Services

301 East Huron, P.O. Box 8647 * Ann Arbor, Michigan * 48107-8647 Fax: (734) 994-8460

DO NOT REMOVE

Any person(s) violating or removing this notice is subject to a fine of not more than \$500.00 and costs of prosecution or by imprisonment for not more than 90 days, or both.

NOTICE OF DANGEROUS BUILDING 111 SOUTH MAIN STREET Ann Arbor MI 48104

- significant water damage to the structure
- saturation of the plywood flooring throughout the visible portions of the west 60' and damage to floor joists
- large tree growing from the roof
- · framing around tree is severely damaged
- majority of plywood subfloor is damaged beyond repair due to water saturation and not adequate as a subfloor material or bracing material to the joists below
- joists in the floor have an un braced compression flange and do not meet strength requirements required for the loading
- localized rotting at the bearing points of the joists where water could accumulate
- gross amount of mold growing throughout the building may make other dangerous conditions not visible

- the structure does not meet building code requirements
- Building has been unoccupied for 180 days or more without being listed for sale or lease

City of Ann Arbor Building Code 8:381 – Dangerous building, prohibitions.

It is unlawful and deemed a public nuisance for any owner or agent thereof to keep or maintain any dangerous building or part thereof as defined in Section 8:382. All dangerous buildings shall be abated by alteration, repair, rehabilitation, demolition or removal in accordance with the procedures specified in this chapter, the City Attorney may prosecute violations of this chapter and may file suit in the appropriate court or pursue any other legal remedies to abate any nuisance resulting from violation of this chapter.

For question and inquires about this notice please contact.

Craig Strong at cstrong @a2gov,org

CITY OF ANN ARBOR

Planning & Development Services
301 East Huron Street, P.O. Box 8647
Ann Arbor, MI 48107-8647

Tel: (734) 794-6267 Fax: (734) 994-8460 Email: <u>BuildingDept@a2gov.org</u>

and/or the Co	the Michigan ode of the City	Building Cod of Ann Arbo	r is hereby	ordered stop		
· Pen	nit u	ithe	vev	per	mit	
Tt be	issus	ved.	a t	ncK(et w	
infraction a	iling to obe and/or a mis rescribed b	demeano				

Building Official/Agent

October 14, 2015

Mr. Craig Strong Code Enforcement Services, Inc. 605 S. Main Street, Ste. 1 Ann Arbor, MI 48104



RE:

111 North Main Street - Non-Structural Demolition Request

Dear Craig,

On behalf of our client, please accept this letter as a formal request to begin non-structural exploratory demolition and abatement in the subject property with the ultimate intent of submitting a formal set of design drawings once the scope and extent of water and mold damage has been identified and mitigated. The Owner and Contractor have been notified that this work shall be limited to non-structural drywall and plaster-lathe and they are not to impact any fire-rated wall assemblies. Existing demising walls shall not be modified except for the non-structural and non-fire-rated furring and drywall.

Sincerely,


Robb Burroughs, RA

Principal

Cc:

Pete Deininger





BUILDING DEPARTMENT 301 E Huron St, P.O. Box 8647 Ann Arbor, MI 48104

Phone: (734) 794-6267 Fax: (734) 994-8460

PLEASE VISIT THE CITY WEB SITE TO SCHEDULE YOUR INSPECTION - WWW.A2GOV.ORG/permits

Permit Number: BLDG15-2104

Construction Type:

Use Group:

Work Type: **DEMOLITION**

Demolition of ALL interior non-bearing walls

Stipulations:

LOCATION	OWNER		
111 S MAIN ST	FEIGELSON LOUIS M		
09-09-29-132-014	PO BOX 7262		
	Ann Arbor, MI 48107		
Approved plans must be retained on job and this card	CONTRACTOR		
kept posted until final inspection has been made. Permits and inspection notices must be posted at a single location on site (electrical panel, etc.). Where a	Deininger Peter Werner 2615 English Oak		
Certificate of Occupancy is required, such building shall not be occupied until final inspection has been approved.	Ann Arbor, MI 48103		
Minimum 24 hour notice required for inspection. You must request inspection.	(734) 323-6937		

Permit Item		Account Num	ber	Fee Basis	Amount
DEMOLITION-ALL STRUCTURES		0026-033-333	30-0000-431	0	150.00
Craig Strong	Date Issued: Date Expires:			Total: ount Paid:	\$150.00 \$150.00
Building Official			BALAN	CE DUE:	\$0.00

I agree this permit is only for the work described and does not grant permission for additional work which requires separate permits. I understand that this permit will become invalid, and null and void if work is not started within 180 days, or if work is suspended or abandoned for a period of 180 days any time after work has commenced, and that I am responsible for assuring all required inspections are requested in conformance with the applicable code.

I hereby cerfity that the proposed work is authorized by the owner, and that I am authorized by the owner to make this application as authorized agent. I agree to conform to all applicable laws of the State of Michigan and local jurisdiction. Al information on the permit application is accurate.

Payment of permit fee constitutes acceptance of above terms.

(12/16/2015 3:14 PM MS)

Met with Peter Pace and Jack from Carlile, Andy Box from fire department.

All four floors are in dangerous condition. floor joists are decaying and broken. Mold on the the walls and flooring are moldy and wet. Flooring on every floor was spongy and in bad shape. Roof is still leaking. On the third floor has support to hold up fourth floor joist, but there was over 50% of broken floor joists. Basement floor joist were decaying and moldy.

Building is in dangerous condition.

CODE15-0268

CODE ENFORCEMENT SERVICES

A division of Carlisle/Wortman Associates, Inc. 605 S. Main Street, Suite 1 Ann Arbor, Michigan 48104

Phone: 734-662-2200 Fax: 734-662-1935

December 16, 2015

Craig Strong - Building Official City of Ann Arbor 100 N. Fifth Ave. Ann Arbor, MI. 48104

RE: 111 S. Main St.

Dear Craig;

I inspected the building located at 111 S. Main Street in Ann Arbor as you requested. I was accompanied on the inspection by Andy Box, Ann Arbor Fire Inspector, Marv Shagawnee, Ann Arbor Building Inspector, Peter Pace of Code Enforcement Services, and Peter Dieninger, the contractor that has a permit to do interior demolition in the building. The purpose of the inspection was to determine if the building was a dangerous building as defined by the City of Ann Arbor building codes being Chapter 101, Section 8:382.

The building is a multistory building of Type III-B construction. The building had roof leaks due to holes in the roof. The interior wall coverings had been removed exposing the roof and floor joists, flooring, and wall structure.

The inspecting revealed the building to be a dangerous building per the City Code, specifically;

- Due to the building being open at the roof water has entered the building and penetrated through all floors. Mold is evident on all the structural floor and roof members, and on the floor system. The existence of the mold renders this building manifestly unsafe for occupancy. Section 8:382 (6).
- 2. Floor and roof joists, and flooring material has deteriorated due to moisture and mold such that they do not have the structural strength to meet the minimum requirements of the Michigan Building Code. Section 8:382 (2)

Based upon these findings it is my opinion the building is a dangerous building under the provisions of the City of Ann Arbor building code. The owner of this building shall be required to appropriately treat the entire interior of the building to eliminate all the mold and mold spores. The owner shall provide the City Building Department with evidence the treatment has eliminated the existence of all the mold. All the structural system including roof, flooring, and partitions within the building should be removed and

replaced with new materials complying with the current building code requirements for structural capabilities for the use intended. The existing exterior walls may remain after the mold remediation.

An alternative to complete removal of all the interior structural system the owner or contractor shall provide the building department with the certification of the structural capabilities of any members they desire to retain. This certification shall be prepared by a structural engineer registered in the State of Michigan and shall clearly delineate which members may remain as they meet the building code strength requirements.

The above work shall be completed and proper documentation shall be provided to the City prior to any occupancy of the building. Proper permits shall be obtained prior to any of the required work commencing.

If you have questions concerning this project please contact me. I can be reached at (734) 223-5103.

Respectfully,

D. Jack Donaldson, P.E. Construction Code Division

1010-2023