

Thursday, October 19, 2017			1:30 PM	Larcom City Hall, 301 E Huron St, Second floor, City Council Chambers	
А	CALL TO OF	RDER			
в	ROLL CALL				
		Present: 5	- Paul Darling, Robert H and Hugh A. Flack Jr.	art, Gordon Berry, David Arnsdorf,	
		Absent: 1	- Chair Kenneth J. Winte	ers	
С	APPROVAL OF AGENDA				
	Approved as presented				
D	APPROVAL	AL OF MINUTES			
D1	<b><u>17-1609</u></b> Building Board of Appeals Meeting Minutes of August 17, 2017			tes of August 17, 2017	
		<u>Attachments</u>	<u>:</u> August 17 2017 BBA N	/lintues.pdf	
		Approved by the Board and forwarded to the City Council due back on 10/30/2017			
Е	PUBLIC CO	PUBLIC COMMENTARY - GENERAL			
F	APPEALS, ACTIONS, AND SHOW CAUSE HEARINGS				
F1	<u>17-1588</u>	BBA17-007 2 19, 2017	28 PACKARD ROAD. VAR	IANCE HEARING OCTOBER	
		<u>Attachments</u>	228 Packard Road Pac	cket October 19, 2017.pdf	
			-	of his property for the appeal or, MI in regards for an appeal	

from R311.7.4.2 of the 2015 Michigan Residential Code for the stairs leading to the third floor to be approved at 8 inches instead of the

required 9 inches.

*Mr. R.* Hart motions that in the matter of the appeal hearing for BBA17-007 for 228 Packard Road, Ann Arbor, Michigan to approve the following variance: the stairs to the third floor shall be permitted to remain with the existing tread depth of 8 inches contrary to Section R311.7.4.2, on the basis that the performance of this particular item or part of the building structure with respect to which the variance is granted will be adequate for its intended use and will not substantially deviate from the performace required by the code for that particular item.

This is granted as a minimum variance from the code only as is necessary to alleviate the exceptional, practical difficulty encountered and shall not be considered a precedent for future similar variances.

## G OLD BUSINESS

NONE

## H NEW BUSINESS

NONE

## I ADJOURNMENT

Adjourn