

ADDENDUM No. 1

ITB No. 4675

Commercial Water Meters

Bids Due: May 4, 2021 by 2:00 P.M. (Local Time)

The information contained herein shall take precedence over the original documents and all previous addenda (if any) and is appended thereto. **This Addendum includes two (2) pages.**

Bidder is to acknowledge receipt of this Addendum No. 1, including all attachments (if any) in its Bid by so indicating on Page 7 of the Invitation to Bid Form. Bids submitted without acknowledgment of receipt of this addendum may be considered nonconforming.

The following forms provided within the ITB Document should be included in submitted bids:

- Vendor Conflict of Interest Disclosure Form
- City of Ann Arbor Non-Discrimination Ordinance Declaration of Compliance

Bids that fail to provide these forms listed above upon bid opening may be rejected as non-responsive and may not be considered for award.

I. QUESTIONS AND ANSWERS

The following Questions have been received by the City. Responses are being provided in accordance with the terms of the ITB. Bidders are directed to take note in their review of the documents of the following questions and City responses as they affect work or details in other areas not specifically referenced here.

Question 1: The Line Item 10 which I think should be Line item 19, titled Totalizer/Rate indicator, will you provide clarification on what you are requesting? Is there a model number or part number you can reference?

Answer 1: The model needs to be compatible with the specified water meter model, no specific totalizer/rate indicator model is specified. One option is the Elster Model RIDA4-20AK but this model is not required.

Question 2: Under specifications manufacturer is states all meters submitted shall be Honeywell evoQ4 electromag meters. Is the City accepting submissions with alternate manufacturers of solid sate ultrasonic/electromag meters?

Answer 2: No

Question 3: Are the 2" meters on the list 2"x 17" lay length or 2"x15.25" lay length?

Answer 3: The city will require the 17" lay length.

Question 4: The list of meters sizes it includes 2.5" meters, is this correct? The typical meter sizing goes from 2" to 3".

Answer 4: This is correct. Our system has a number of 2.5" meters within it. If the size is not available, do not provide a price for it.

Question 5: Is the city is willing to accept an alternate to the EVO Q4?

Answer 5: No

Question 6: On page 10. Bolts and Fasteners – Does the city want all of the flange packs which consists of flanges, gaskets, bolts and nuts to be included with the meters

Answer 6: Yes

Question 7: We will be supplying pricing for nuts, bolts and gaskets, less flanges. Do we include the pricing in the meter price or separate price?

Answer 7: Pricing should be included in the price of the water meter.

Bidders are responsible for any conclusions that they may draw from the information contained in the Addendum.