

From: Summersgill, Kathleen
Sent: Tuesday, April 17, 2018 1:34 PM
To: Scott Betzoldt
Cc: jeff garno Ted P. Hirsch
Subject: RE: 2050 Commerce - Dimensional Site Plan

Scott,

I reviewed this project in November, 2017 based on the two fire access roads as shown on the west and east. Due to the size and layout of the building, both are necessary for aerial fire apparatus access roads and both qualify as such under the 2015 International Fire Code, Appendix D105 and D106.

Regards,

Kathleen

*Kathleen Summersgill
Fire Marshal
Ann Arbor Fire Department
1510 E. Stadium Blvd. Ann Arbor, MI 48104
(734)794-6962*