



# ACCESS CUSTOMER SUPPORT

Date:	3-17-2025
Proposal No	093SN-25-0317
Contact	Adam Smith
Phone	734-845-0335
Fax	
Email	
Term	

## LIEBERT SYSTEM SERVICE

**Location:** Ann Arbor WWTP  
**Contact:** Adam Smith  
**Site Address:** 49 S Dixboro rd  
**City/State/Zip:** Ann Arbor, MI 48105

**Bill To:** \_\_\_\_\_  
**Contact:** \_\_\_\_\_  
**Address:** \_\_\_\_\_  
**City/State/Zip:** \_\_\_\_\_

**ACCESS MICHIGAN LLC** agrees to furnish all labor, material and supervision necessary to perform regularly scheduled maintenance as outlined below. To be performed by a **Liebert factory trained technician**.

Subject – Liebert Repairs  
M#VS042KSA0E0041A  
S# C14F8H0042  
Repairs to Circuit #1 and Circuit #2  
Scope of work –

- Lock out tag out power to unit
- Recover refrigerant and dispose of it to EPA standards
- Cut out failed paradenser
- Provide and install new OEM paradenser
- Rebuild both 3-way valves
- Replace liquid line driers
- Pressure test and vac down
- Weigh in factory charge of virgin 407C
- Top off system with glycol – 55-gallon barrel of pure concentrate glycol to be left on site
- Perform start up and test operation

Total Price - \$39,884.00



# ACCESS CUSTOMER SUPPORT

Payment terms are Net 30 days from date of invoice. This agreement contains the entire program and shall become effective upon acceptance by Customer and commencement of services. Access Customer Support LLC maintenance service terms and conditions shall become effective upon acceptance by customer. Refer to attached for terms and conditions.

Signature **Theresa Paros/Steve Nowak**

Name Theresa Paros/Steve Nowak

Date 3-17-2024

Accepted By:  
Customer

Signature \_\_\_\_\_

PO# \_\_\_\_\_

Date \_\_\_\_\_